


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 529

Dated: 02/01/2024

It is certified that an inspection team headed by Chief municipal officer
 (Name of Officers with designation) from Nagar panchayat Naya Baradwar
 (Name of Department/ Office) inspected the ASIAN world School, Vill-Naya -
- Baradwar, Dist Sakti (C.G.)
 (Name & Address of the school) on (date of inspection) and found that the
Asian world School (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal: 

Name

मुख्य नगर पालिका अधिकारी

शिव कुमार पाल

Designation

Chief municipal officer

Name & Address of the Office / Department : Baradwar

To

The PrincipalAsian world School, Naya Baradwar Dist Sakti (C.G.)

(Name & Address of the Institution)

495687

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



PRINCIPAL
 Asian World School
 Naya Baradwar
 Dist - Sakti(C.G) 495 687



Manager
 AsianWorld School
 Baradwar (C.G.) 495687



District Water Testing Laboratory
Public Health Engineering Department ,
PHE, Barpali Chowk in Front Gurudwara, Janjgir-Champa (C.G.)
Contact as email – eejan-phe-cg@nic.in

Test Report

Kind of sample- Drinking water sample	Report no. 426	Sampled by..:- Dhananjay Kumar Bhardwaj	ULR No. :- TC1037423000000426F	
	Senders letter no./Date	1157/08/12/2023	Source –	Power Pump
	DWTL receipt no.	426	DWTL Receipt date	11/12/2023
	Date of analysis started	11/12/2023	Date of analysis completed	13/12/2023

Sample Details:-

Sr.no.	Sample I.D.	District /Block	City / Village	Location/source no./GPS identification
1	DWTL/PHED/JC/3056	Sakti	Naya Baradwar	Asian World School, Naya Baradwar
2				
3				
4				
5				

Details of parameters their test method units and specification as per IS/APHA :-

Sr. no.	Parameters	Test method		Unit	As per IS-10500-2012 drinking water		Result of S.no.				
		Method	Part no.		Desir able Limit	Permis sible Limit	1	2	3	4	5
1	2	3	4	5	6	7	-	-	-	-	-
1	Turbidity	IS:3025	Part-10	NTU	1	5	1.94				
2	Colour	APHA:23rd ed	Part - 2120B	Hazen	5	15	02				
3	Odour	IS:3025	Part - 05	Unobje nable	Agr.	Agr.	Agr.				
4	pH	IS:3025	Part - 11	pH scale	6.5 - 8.5	6.5 - 8.5	7.32				
5	Total Alkalinity as CaCO ₃	APHA:23rd ed	Part – 2320 B	mg/l.	200	600	133.55				
6	TDS	APHA:23rd ed	Part - 2540 - C	mg/l.	500	2000	368				
7	Chloride as Cl ⁻	APHA:23rd ed	Part – 4500 - C	mg/l.	250	1000	54.26				
8	Total Hardness as CaCO ₃	APHA:23rd ed	Part – 2340 - C	mg/l.	200	600	180.13				
9	Calcium as Ca ⁺⁺	APHA:23rd ed	Part – 3500-Ca	mg/l.	75	200	44.61				
10	Magnesium as Mg ⁺⁺	APHA:23rd ed	3500 - Mg - B	mg/l.	30	100	16.72				

- 1 The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- 3 The results refer only to tested samples and parameters.
4. This Lab does not hold any responsibility for verification in results for samples kept on hold for wants of clarification.
5. Samples will be stored for a period of 10 days from date of issue of report

Issu No. 426 Page No.01, Date 14.12.2023

PRINCIPAL

Asian World School
Naya Baradwar
Dist - Sakti(C.G) 495 687

Manager

AsianWorld School
Baradwar (C.G.) 495687

District Authorized Signatory (NABL)
PHE Janjgir-Champa (C.G.)

District Water Testing Laboratory
Public Health Engineering Department ,
PHE. Barpali Chowk in Front Gurudwara, Janjgir-Champa (C.G.)
Contact as email – eejan-phe-cg@nic.in

Test Report

Kind of sample- Drinking water sample	Report no. 426		Sampled by.. Dhananjay Kumar Bhardwaj	
Senders name & address :- CMO Nagar Palika Officer, Nagar Panchayat, Naya Baradwar Block- Sakti, Distt.- Sakti (C.G.)	Senders letter no./Date	1157/11/12/2023	Source –	Power Pump
	Sample collection date	11/12/2023	DWTL Reciept date	11/12/2023
	DWTL receipt no.	426	Date of analysis completed	13/12/2023
	Date of analysis started	11/12/2023		

Sample Details:-


Sr.no.	Sample I.D.	District /Block	City / Village	Location/source no./GPS identification
1	DWTL/PHED/JC/3056	Sakti	Naya Baradwar	Asian World School, Naya Baradwar
2				
3				
4				
5				


Details of parameters their test method units and specification as per IS/APHA :-

s.n.	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 drinking water		Result of S.no.				
		Method	Part no.		Desir able Limit	Permis sible LLimit	1	2	3	4	5
1	2	3	4	5	6	7	-	-	-	-	-
1	Taste	IS:3025	Part - 8	Unobje nable	Agr.	Agr.	Agr.				
2	Nitrates as NO ₃ ⁻	APHA 23rd ed	4500-NO ₃ ⁻ B	mg/l.	45	No relaxat ion	02				
3	Iron as Fe ⁺⁺	APHA 23rd ed	3500 -Fe -B	mg/l.	1.0	No relaxat ion	0.03				
4	Sulphate as SO ₄ ²⁻	APHA 23rd ed	Part- 24	mg/l.	200	400	02				
5	Fluoride as F ⁻	APHA 23rd ed	4500-F ⁻ C	mg/l.	1.0	1.5	0.01				
6	Residual Chlorine	-	-	mg/l.	0.2	1.0	0.0				
7	Spe.Conductivity	APHA:23rd ed	Part- 14	µmho/cm	-	-	738				

- 1 The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- 3 The results refer only to tested samples and parameters.
4. This Lab does not hold any responsibility for verification in results for samples kept on hold for wants of clarification.
5. Samples will be stored for a period of 10 days from date of issue of report

Issu No. 426 Page No.02, Date 14.12.2023


Chemist
District Water Testing Laboratory
PHED, Janjgir-Champa (C.G.)
PHE Janjgir-Champa (C.G.)


PRINCIPAL
Asian World School
Naya Baradwar
Dist - Sakti (C G) 495 687


Manager
AsianWorld School
Baradwar (C.G.) 495687

District Water Testing Laboratory
Public Health Engineering Department ,
PHE. Barpali Chowk in Front Gurudwara, Janjgir-Champa (C.G.)
Contact as email – eejan-phe-cg@nic.in

Bacteriological-Test Report

Kind of sample- Drinking water sample	Report no. 426	Sampled by.. Dhananjay Kumar Bhardwaj		
Senders name & address -: CMO Nagar Palika Officer, Nagar Panchayat, Naya Baradwar Block- Sakti, Distt.- Sakti (C.G.)	Senders letter no./Date	1157/11/12/2023	Source –	Power Pump
	Sample collection date	11/12/2023	DWTL Reciept date	11/12/2023
	DWTL receipt no.	426	Date of analysis completed	13/12/2023
	Date of analysis started	11/12/2023		

Sample Details:-

Sr.no.	Sample I.D.	District /Block	City / Village	Location/source no./GPS identification
1	DWTL/PHED/JC/3056	Sakti	Naya Baradwar	Asian World School, Naya Baradwar
2				
3				
4				
5				


Details of parameters their test method units and specification as per IS/APHA :-

s.n.	Parameters	Test method IS:3025/APHA 23rd ed.		As per IS-10500-2012 drinking water		Result of S.no.				
		Method	Unit	Desirable Limit	Permissible Limit	1	2	3	4	5
1						-	-	-	-	-
1	Total Coliform	APHA/IS	Cfu/100ml	nil	nil	0.0				

- 1 The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
- 3 The results refer only to tested samples and parameters.
4. This Lab does not hold any responsibility for verification in results for samples kept on hold for wants of clarification.
5. Samples will be stored for a period of 10 days from date of issue of report

Issu No. 426 Page No.03, Date 14.12.2023


Chemist
District Water Testing Laboratory
PHED, Janjgir-Champa (C.G.)
PHE Janjgir-Champa (C.G.)


PRINCIPAL
Asian World School
Naya Baradwar
Sakti - Sakti(C.G) 495 687


Manager
AsianWorld School
Baradwar (C.G.) 495687

कार्यालय सहायक अभियंता, लोक स्वास्थ्य यांत्रिकी उपखण्ड – चांपा
जिला-जांजगीर-चांपा (छ.ग.)

क्र. 445 / लेब / स.अ. / लो.स्वा.यां. / उपखण्ड / चांपा / 2023 दिनांक 14.12.23

प्रोफार्मा बिल
जिला जल परीक्षण प्रयोगशाला


प्रति,


मुख्य नगर पालिका अधिकारी
नगर पंचायत नया बाराद्वार
वि.ख. – बलौदा
जिला – जांजगीर-चांपा (छ.ग.)

संदर्भ :- आपका पत्र क्र. 1157 दिनांक 08/12/2023 एवं लेब का आवक क्र. 426

क्रमांक	पैरामीटर	जल नमूनों की संख्या	राशि
1	समान्य भौतिक, रासायनिक एवं जीवाणु परीक्षण	01 नग	500 रु.
(रु. पांच सौ रुपये मात्र)		टोटल :-	500 रु.

नोट :- कृपया भुगतान हेतु चेक/ड्राफ/नगद
सहायक अभियंता, लोक स्वास्थ्य यांत्रिकी उपखण्ड-चांपा (छ.ग.) को प्रदाय किया गया।


सहायक अभियंता
लोक स्वास्थ्य यांत्रिकी उपखण्ड
चांपा (छ.ग.)


PRINCIPAL
Asian World School
Naya Baradwar
Sakti(C G) 495 687


Manager
World School
C.G. 495687